## TOP TEN INSPECTION FAILS

## Avoid these inspection fails! Make sure your property has:

- 1. Functioning smoke and carbon monoxide detectors.
- 2. Windows that open and shut without being propped up. Locks and screens are also required.
- 3. Handrails where there are four or more steps inside and outside the building.
- 4. A window or a working ventilation fan in the bathroom.
- 5. No locks on interior doors that could result in a person being unable to exit a room.
- 6. Flooring that is free of trip hazards. Bathroom and kitchen floors must be watertight and easy to clean.
- Heat must be operational between September 15 and June 15 at a minimum of 68° F. Hot water must be functional and between 110-130° F.
- 8. Weather-tight, caulked doors and windows. Plumbing that is free of leaks.
- 9. A stove that works properly and is clean.
- 10. Lights on the exterior of the building both front and rear.

This list of items that commonly result in a failed inspection was compiled by the Inspectional Services team at Metro Housing|Boston. The team conducts more than 20,000 inspections a year in Boston and the surrounding communities.

Learn more about our work at www.metrohousingboston.org.